



To: Planholders for Belvidere Park District Front Parking Lot Repairs **via Email ONLY**  
CC: Jonathan Cudzewicz, Gunnar Morris  
From: Jeff Linkenheld, Arc Design Resources  
Date: July 28, 2022  
Re: Addendum 2

---

This addendum forms a part of the Bidding and Contract Documents and modifies the original bidding documents issued on June 23, 2022. Acknowledge receipt of this addendum in space provided by returning the attached acknowledgement form with your bid. FAILURE TO ACKNOWLEDGE RECEIPT OF ADDENDA MAY DISQUALIFY BID.

#### **Additional Clarifications based on Contractor questions**

The following clarifications arose from additional contractor questions received after the issuance of addendum 1:

- The contractor can utilize AIA Bid Bond or other appropriate bid bond form with his submittal. Does not have to be the Park District form.
- City of Belvidere has reviewed the plans and the painted parking stalls are to be reduced from 20' stripes to 19' stripes. This increased the center drive aisle from 24' to 26'. The overall width of the lot does not change.
- Beneath the heated sidewalk area on the site, there will need to be some foam insulation board installed. This was not shown on any detail. Contractor shall plan for a full core out of the heated sidewalk area that includes the sidewalk thickness, then an underlying 2" layer of foamboard insulation, then the stone base. Change the stone base below the heated sidewalk area and foamboard to CA-7 so it is well graded and does not trap water below the foamboard.
- There was a miscommunication at the pre-bid meeting that was relayed in addendum 1. Per the drawings all new steel shall be galvanized. The instructions to prime were erroneous. As a reminder, any painting will be done at a later date by the owner.
- The screws to fasten the floor plates to the tube steel is called out on number 9 of the structural steel notes.
  - "Fasten steel plate to structure w/ #12 Tek Screws @ 12" O.C. all along supports"
- For the 3x3 to 6x4 connections, we shall use (2) ¼" Tek screws @ each end of each joist.

#### **Bids Due**

Reminder that bids are due at the Belvidere Park District at **10:00 am on Tuesday August 2, 2022**. The project would be considered by the Board at their first meeting in August.

End of Addendum 2

RETURN WITH BID

ACKNOWLEDGEMENT OF RECEIPT OF  
ADDENDUM AND FINAL BID FORM

For General Contractor: Sign and return this acknowledgement with your bid proposal.

The undersigned hereby acknowledges receipt of Addendum 2, as published by Arc Design Resources on Thursday July 28, 2022, which has been used in preparation of our enclosed bid.

For: \_\_\_\_\_  
Contractor Firm Name

By: \_\_\_\_\_  
Signature of Authorized Person

Date: \_\_\_\_\_